

Screws in Ecocon panel calculation for a traverse connection

Wood type:	C24
Width of wooden element:	$t_1 := 25 \cdot \text{mm}$
Height of wooden element:	$t_2 := 45 \cdot \text{mm}$
Screw angle:	$\alpha := 0 \cdot \text{deg}$
Screw length:	$l_s := 80 \cdot \text{mm}$
Screw diameter:	$d := 8 \cdot \text{mm}$
Threaded part of the screw 8,0x80:	$l_{g.3} := 50 \text{ mm}$
	$l_{ef.3} := l_{g.3} - d = 42 \text{ mm}$
Charac. density of the timber	$q_k := 350 \cdot \frac{\text{kg}}{\text{m}^3}$
Partial factor for material properties:	$\gamma_M := 1.30$
Charac. tensile strength of each screw:	$f_{u.k} := 600 \cdot \text{MPa}$
Charac. load-carrying capacity of axially loaded screw:	$f_{c.90.k} := 5.1 \cdot \text{MPa}$
Material factor for connections:	$\gamma_{M.connection} := 1.3$
Factor for duration loading and service:	$k_{mod} := 0.6$

Axial design withdrawal capacity of the screw

$$f_{ax.k} := 3.6 \cdot 10^{-3} \cdot \left(q_k \cdot \frac{\text{m}^3}{\text{kg}} \right)^{1.5} \cdot \text{N} \cdot \text{mm}^{-2} = 23.572 \text{ MPa}$$

$$f_{ax.a.k} := \frac{f_{ax.k}}{(\sin(\alpha))^2 + 1.5 \cdot (\cos(\alpha))^2} = 15.715 \text{ MPa}$$

For screw 8,0x80mm:

$$\beta := 1$$

$$F_{ax.a.Rk} := \left(\pi \cdot d \cdot l_{ef.3} \cdot \text{mm}^{-2} \right)^{0.8} \cdot f_{ax.a.k} \cdot \text{mm}^2 = 4.122 \text{ kN}$$

$$F_{ax.Rd.1} := \frac{F_{ax.a.Rk} \cdot k_{mod}}{\gamma_{M.connection}} = 1.902 \text{ kN}$$

Maximal axial tensional load in connection:

$$F_{ax.Rd} := F_{ax.Rd.1} \cdot 2 = 3.805 \text{ kN}$$

Embedment strength of timber

$$f_{h,k} := 0.082 \cdot \left(q_k \cdot \frac{m^3}{kg} \right) \cdot (d \cdot mm^{-1})^{-0.3} \cdot N \cdot mm^{-2} = 15.38 \text{ MPa}$$

Yield moment of a screw

$$M_{y,Rk} := 0.15 \cdot \left(f_{u,k} \cdot \frac{mm^2}{N} \right) \cdot (d \cdot mm^{-1})^{2.6} \cdot N \cdot mm = (2.006 \cdot 10^4) \text{ N} \cdot mm$$

Shear strength for the screw 8,0x80

Failure mode (a): $F_{v,Rk,a} := f_{h,k} \cdot t_1 \cdot d = 3.076 \text{ kN}$

Failure mode (b): $F_{v,Rk,b} := f_{h,k} \cdot t_2 \cdot d = 5.537 \text{ kN}$

Failure mode (c):

$$F_{v,Rk,c} := \frac{f_{h,k} \cdot t_1 \cdot d}{1 + \beta} \cdot \left(\sqrt{\beta + 2 \cdot \beta^2 \cdot \left(1 + \frac{t_2}{t_1} + \left(\frac{t_2}{t_1} \right)^2 \right) + \beta^3 \cdot \left(\frac{t_2}{t_1} \right)^2} - \beta \cdot \left(1 + \left(\frac{t_2}{t_1} \right) \right) \right) + \frac{F_{ax,a,Rk}}{4} = 2.937 \text{ kN}$$

$$F_{v,Rk,d} := 1.05 \cdot \frac{f_{h,k} \cdot t_1 \cdot d}{2 + \beta} \cdot \left(\sqrt{2 \cdot \beta \cdot (1 + \beta) + \frac{4 \cdot \beta \cdot (2 + \beta) \cdot M_{y,Rk}}{f_{h,k} \cdot t_1^2 \cdot d}} - \beta \right) + \frac{F_{ax,a,Rk}}{4} = 2.829 \text{ kN}$$

$$F_{v,Rk,e} := 1.05 \cdot \frac{f_{h,k} \cdot t_2 \cdot d}{1 + 2 \cdot \beta} \cdot \left(\sqrt{2 \cdot \beta^2 \cdot (1 + \beta) + \frac{4 \cdot \beta \cdot (1 + 2 \cdot \beta) \cdot M_{y,Rk}}{f_{h,k} \cdot t_2^2 \cdot d}} - \beta \right) + \frac{F_{ax,a,Rk}}{4} = 3.411 \text{ kN}$$

$$F_{v,Rk,f} := 1.15 \cdot \left(\sqrt{\frac{2 \cdot \beta}{1 + \beta} \cdot (2 \cdot M_{y,Rk} \cdot f_{h,k} \cdot d)} \right) + \frac{F_{ax,a,Rk}}{4} = 3.585 \text{ kN}$$

$$F_{v,Rk} := \min(F_{v,Rk,a}, F_{v,Rk,b}, F_{v,Rk,c}, F_{v,Rk,d}, F_{v,Rk,e}, F_{v,Rk,f}) = 2.829 \text{ kN}$$

$$F_{v,Rd,1} := \frac{F_{v,Rk} \cdot k_{mod}}{Y_{M,connection}} = 1.306 \text{ kN}$$

Shear strength of the connection

$$F_{v.Rd} := F_{v.Rd.1} \cdot 2 = 2.611 \text{ kN}$$

$$N_{R.d} := \min(F_{v.Rd}, F_{ax.Rd}) = 2.611 \text{ kN}$$

