

# Attestation

## CDPH CA01350

On the 23<sup>rd</sup> of April 2025, Eurofins Product Testing A/S received a sample of wood-based panel with the product name:

### EcoCocon Straw Panel

supplied by

### EcoCocon

The emissions were tested according to CDPH Section 01350. Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2025-00204101\_H\_EN).

#### Evaluation of the emission test result according to CDPH Section 01350 / CA01350

- No carcinogens and reproductive/developmental toxins could be detected.
- No individual compound exceeds one-half of the lowest concentrations of interest in a building (chronic REL).
- The requirements were passed both in reference to classrooms and office buildings.

The tested product complies with the requirements of the "Standard method for the testing and evaluation of volatile organic chemical emissions from indoor sources using environmental chambers (version 1.2)" as defined by the California Department of Public Health (CDPH) – Version of January 2017.

3 June 2025



Claus Bonde  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager